



AFFILIATIONS:
 AMERICAN WATER WORKS ASSOCIATION
 AMERICAN SOCIETY FOR TESTING AND MATERIALS
 MICHIGAN GROUND WATER ASSOCIATION
 AMERICAN ACADEMY OF INDEPENDENT LABORATORIES
 WATER QUALITY ASSOCIATION
 SAFE DRINKING WATER FOUNDATION
 WATER ENVIRONMENT FEDERATION

TO: Mr. Valued Customer
RE: 1425 Any Street, Bluewater

DATE: May 1, 2009
SAMPLE NO: 4932

**Thank you for giving us the opportunity to test your water sample.
 We are pleased to provide you with the test results.**

ANALYTICAL REPORT

	PARAMETER	MCL	RESULT	READING
1.	Total Coliform Bacteria	0	Acceptable	Not Detected
2.	E-Coli Bacteria	0	Acceptable	Not Detected
3.	Nitrates	10 ppm	Acceptable	3.2 ppm
4.	Nitrites	1 ppm	Acceptable	0.7 ppm
5.	Nitrate/Nitrites Total	10 ppm	Acceptable	3.9 ppm
6.	Lead	15 ppb*	Acceptable	Not Detected
7.	Sodium	200 ppm ¹	Acceptable	16.5 ppm
8.	Arsenic	10 ppb	Acceptable	8 ppb
9.	Turbidity	5 units	Acceptable	<1 unit

MCL= Maximum Contaminant Level set by the EPA ppm = parts per million ppb = parts per billion
 Report Limits: nitrate 0.8 ppm; nitrite 0.1 ppm; bacteria 1 colony; lead 3 ppb; sodium 8 ppm, arsenic 3 ppb
 *EPA Action level ¹ World Health Organization guideline

All analytical data, unless otherwise indicated, meets EPA drinking water criteria

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.
 Reproduction of this analytical report is permitted only in its entirety.

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9910
9165 HIGHLAND ROAD, WHITE LAKE, MI 48386 248-698-9500 FAX 248-698-9772